ELEVATOR INSPECTION FORM

Quality Elevator Inspections, Inc.
State Licensed
516 North Point Ct. Chatham, IL 62629
217.481.0701

Date: 7-10-18
Code Edition: ASME A 17.1 _____ A17.3 _____
V/T/C
ID # _____ Convey # 122071
Inspection & Test ☐ Routine ☑ Periodic ☐ Acceptance

Address: 110 Ivy ST
Unit
Bldg. Name: Victoria Manor
Make: Thyssen
Power: Hydro
FL/PT
Bldg. Rep.
Speed _____ fpm
Capacity: 2500
Em Ph: No
Phone No.
Em Light

		OK	NG	NA
1.	**ELEVATOR-INSIDE OF CAR**			
1.1	Door reopening device	☑	☐	☐
1.2	Stop switches	☑	☐	☐
1.3	Operating control devices	☑	☐	☐
1.4	Sills & car floor	☑	☐	☐
1.5	Car lighting & receptacles	☑	☐	☑
1.6	Car emergency signal-lighting	☐	☒	☐
1.7	Car door or gate	☑	☐	☐
1.8	Door closing force	☑	☐	☐
1.9	Power closing of doors or gates	☑	☐	☐
1.10	Power opening of doors or gates	☑	☐	☐
1.11	Car vision panels & glass car doors	☐	☐	☑
1.12	Car enclosure	☑	☐	☐
1.13	Emergency exit	☑	☐	☐
1.14	Ventilation	☑	☐	☐
1.15	Signs & operating device symbols	☑	☐	☐
1.16	Rated load, platform area, & data plate	☑	☐	☐
1.17	Standby power operation	☐	☐	☑
1.18	Restricted opening of car or hoistway doors	☑	☐	☐
1.19	Car Ride	☑	☐	☐
2.	**ELEVATOR-MACHINE ROOM**			
2.1	Access to machine space	☑	☐	☐
2.2	Headroom	☑	☐	☐
2.3	Lighting & receptacles	☑	☐	☐
2.4	Machine space	☑	☐	☐
2.5	Housekeeping	☑	☐	☐
2.6	Ventilation	☑	☐	☐
2.7	Fire extinguisher	☑	☐	☐
2.8	Pipes, wiring, & ducts	☑	☐	☐
2.9	Guarding of exposed auxiliary equipment	☑	☐	☐
2.10	#ing of elevators, machines, disconnects	☑	☐	☐
2.11	Disconnecting means & control	☑	☐	☐
1.12	Controller wiring, fuses, grounding, etc.	☑	☐	☐
2.13	Governor, overspeed switch, & seal	☐	☐	☐
2.14	Code data plate	☑	☐	☐
2.15	(T) Static control	☐	☐	☑
2.16	(T) Overhead beam & fastenings	☐	☐	☑
2.17	(T) Drive machine brake	☐	☐	☑
2.18	(T) Traction drive machines	☐	☐	☑
2.19	(T) Gears, bearings, & flexible coupling	☐	☐	☑
2.20	(T) Winding drum mach & slack cable dev	☐	☐	☑
2.21	(T) Belt or chain-drive machine	☐	☐	☑
2.22	(T) Motor generator	☐	☐	☑
2.23	(T) Absorption of regenerated power	☐	☐	☑
2.24	(T) AC drives from a DC source	☐	☐	☑
2.25	(T) Traction sheaves	☐	☐	☑
2.26	(T) Secondary & deflector sheaves	☐	☑	☑
2.27	(T) Rope fastenings	☐	☐	☑
2.28	(T) Terminal stopping devices	☐	☐	☑
2.29	(T) Car & counterweight safeties	☐	☐	☑
2.30	Hydraulic power unit	☑	☐	☐
2.31	Relief valves 440	☑	☐	☐
2.32	Control valve	☑	☐	☐
2.33	Tanks	☑	☐	☐
2.34	Flexible hydr hose & fitting assemblies	☐	☐	☑
2.35	Supply line & shutoff valve	☑	☐	☐
2.36	Hydraulic cylinders	☑	☐	☐
2.37	Pressure switch	☑	☐	☐
2.38	Roped water hydraulic elevators	☐	☐	☑
2.39	Low oil protection	☑	☐	☐
2.40	Inspection control	☐	☐	☑
2.41	Maintenance records	☑	☐	☐
2.42	Static control	☐	☐	☑
3.	**ELEVATOR-TOP OF CAR**			
3.1	Top-of-car stop switch	☑	☐	☐
3.2	Car top light & outlet	☑	☐	☐
3.3	Top-of-car operating device	☑	☐	☐
3.4	Normal terminal stopping devices	☑	☐	☐
3.5	Clearance, refuge space standard railing	☑	☐	☐
3.6	Final & emerg terminal stopping devices	☑	☐	☑
3.7	Car leveling & anticreep devices	☑	☐	☐
3.8	Top emergency exit	☑	☐	☐
3.9	Floor & emerg identification numbering	☑	☐	☐
3.10	Hoistway construction	☑	☐	☐
3.11	Hoistway smoke control	☐	☐	☑
3.12	Pipes, wiring & ducts	☑	☐	☐
3.13	Windows, projections, recesses, & setbacks	☑	☐	☐
3.14	Hoistway clearances	☑	☐	☐
3.15	Multiple hoistways	☐	☐	☑
3.16	Traveling cables & junction boxes	☑	☐	☐
3.17	Door & gate equipment	☑	☐	☐
3.18	Car frame & stiles	☑	☐	☐
3.19	Guide rails fastening & equipment	☑	☐	☐
3.20	Governor rope	☐	☐	☑
3.21	Governor releasing carrier	☐	☐	☑
3.22	Wire rope fastening & hitch plate	☐	☐	☑
3.23	Suspension rope	☐	☐	☑
3.24	(T) Top counterweight clearance	☐	☐	☑
3.25	(T) Car, overhead, & deflector sheaves	☐	☐	☑
3.26	(T) Broken rope, chain, or tape switch	☐	☐	☑
3.27	Crosshead data plate & rope data tags	☐	☐	☑
3.28	Counterweight & counterweight buffer	☐	☐	☑
3.29	Counterweight safeties	☐	☐	☑
3.30	Speed test	☐	☐	☑
3.31	Slack rope device-roped hydr elevs (*)	☐	☐	☑
3.32	Traveling sheave-roped hydr elevs (*)	☐	☐	☑
3.33	(T) Compensating ropes & chains	☐	☐	☑
4.	**ELEVATOR-OUTSIDE HOISTWAY**			
4.1	Car platform guard	☑	☐	☐
4.2	Hoistway doors	☑	☐	☐
4.3	Vision panels	☐	☐	☑
4.4	Hoistway door locking devices	☑	☐	☐
4.5	Access to hoistway	☑	☐	☐
4.6	Power closing of hoistway doors	☑	☐	☐
4.7	Sequence operation	☐	☐	☑
4.8	Hoistway enclosure	☑	☐	☐
4.9	Elevator Parking devices	☐	☐	☑
4.10	Emergency doors in blind hoistways	☐	☐	☑
4.11	(T) Separate counterweight hoistway	☐	☐	☑
4.12	Standby power selection switch	☐	☐	☑
4.13	Inspection control	☐	☐	☑
5.	**ELEVATOR-PIT**			
5.1	Pit access, lighting, stop switch, & condition	☑	☐	☐
5.2	Bottom clearance, runby & min. refuge space	☑	☐	☐
5.3	(T) Final & emergency terminal stopping devices	☐	☐	☑
5.4	Normal terminal stopping devices	☑	☐	☐
5.5	Traveling cables	☑	☐	☐
5.6	Governor-rope tension devices	☐	☐	☑
5.7	Car Frame & platform	☑	☐	☐
5.8	Car safeties & guiding memb-incl roped-hydr elev(*)	☐	☐	☑
5.9	(T) Buffers & emerg terminal speed limiting devices	☐	☐	☑
5.10	(T) Compensating chains, ropes & sheaves	☐	☐	☑
5.11	Plunger & cylinder	☑	☐	☐
5.12	Car buffer	☑	☐	☐
5.13	Guiding members	☑	☐	☐
5.14	Supply piping	☐	☐	☐
6.	**ELEVATOR-FIRE SERVICE**			
6.1	☐ A17.1b-1973 thru A17.1b	☐	☐	☐
6.2	☐ A17.1-1981 thru A17.1b-1983	☐	☐	☐
6.3	☐ A17.1-1984 thru A17.1a-1988 & A17.3	☐	☐	☐
6.4	☑ A17.1b-1989 thru A17.1d-2000	☑	☐	☐

COMMENTS:

OK-meets requirement NG-insert number to identify comment NA-not applicable (T) Traction Cars (*) installed under A17.1b-1989 and later editions

Line not working

No active Phone Line

THIS IS THE OFFICIAL INSPECTION FORM APPROVED BY THE OFFICE OF THE STATE FIRE MARSHAL, DIVISION OF ELEVATOR SAFETY.
THE ELEVATOR SAFETY ACT PA 92-0873/120 MANDATES EACH CONVEYANCE BE INSPECTED ANNUALLY.

☒ FAIL - RE-INSPECT IN 30 DAYS
☐ PASS - CONDITION GOOD-
Approved for Certificate

Elevator Company Representative: [illegible]
Inspector's Signature: [illegible]
Elev Co Lic # IL
Inspector QEI#
Elev Mech Lic # IL
Inspector's Lic # IL